

## Lightning Strikes and Metal Roofing

### Overview

In every aspect of our daily lives, we are surrounded by electronics. Whether the television we're watching, the computer we're working on, or the lights we are reading by, our lives are dependent on electricity in both our homes and workplace. Taking this into consideration, a lightning strike on an occupied building is a concern not only for the electronics surrounding us, but for the risk of fire caused by that strike. Concern over the use of metal roofs in construction has raised the issue of whether metal roofs attract lightning strikes more than other types of roofing materials.

Research has shown that the material used in roof construction does not influence the risk of a lightning strike. There are several other factors that may influence the risk of a lightning strike that will be discussed however the presence of a metal roof may actually be beneficial in a situation where a lightning strike has taken place.

### Discussion

Concern over the impact of effect of lightning and lightning strikes is not a new item. Research and the earliest comments on the effect of lightning go back to 1752 when Benjamin Franklin performed his famous "kite and key" experiments. Franklin's original idea was to use a sharp point to draw charges from a cloud and then discharge that charge to prevent lightning and lightning strikes that could cause far greater loss of property and life.

Generally speaking, lightning is a flow of negatively charged electrons from the clouds looking for the path of least resistance to the positively charged surface of the earth. The visible means of transport is a lightning bolt that can carry millions of volts of devastating power. While the

dramatic part of the strike is the flash of light, the average length of a lightning flash is only about 30 microseconds. Though short in duration, the overall impact of a lightning strike can be tremendous. If the electrical charge is strong enough and no continuous direct path is available, lightning can also arc from one material to another. Resistance to this flow of electricity generates heat energy that may cause explosions, fires, and other significant damage.

A great deal of research has gone into the science of lightning protection in the 20<sup>th</sup> century. Most notable is the creation of a standard to determine the level of hazard and where lightning protection is most required and how lightning protection should be installed on a structure (NFPA 780). Development of a model for lightning protection has also been developed and incorporated into some European standards since the early 1960's (Horvath). Finally, the development of a National Lightning Detection Network (NLDN) in the 1990's resulting from university research going back to the 1970's had greatly improved the understanding of lightning and lightning strikes.

In assessing the risk of a lightning strike, two different areas of concern need to be analyzed.

- *Probability* of a lightning strike
- *Consequence* of a lightning strike.

The use of lightning protection systems have been shown over many years of experience to lessen consequence of a strike.

### **Probability of a lightning strike**

There are no practical measures known that can lessen the probability of a lightning strike.

The probability for a building to experience a lightning strike is influenced by a number of significant factors:

1. **Area Topography:** The probability of a lightning strike is increased when the subject building is located on an elevated site such as a mountain or hilltop as lightning is drawn towards the highest object in a strike area.
2. **Height of the Building:** A tall building, relative to other structures in the surrounding area is more likely to have a lightning strike than a building that is the same relative height as surrounding structures (buildings, trees, towers, etc.) The presence of a very tall structure in proximity to a small, short building will tend to reduce the likelihood of a strike to the small building.
3. **Size of the Building:** While not necessarily the tallest structure in a strike area, those buildings covering a larger surface area provide a more accessible target for lightning strikes.
4. **Frequency/Severity of Thunderstorm Activity:** Certain geographic areas are more prone to the development of storms that lead to lightning and lightning strikes.

Note that none of the significant factors above include the material used in construction of the roof. Metal roofs **do not** attract lightning strikes; nor do metal roofs protect a building against lightning.

***A metal roof is no more or less likely to get struck by lightning.***

Based on the factors listed above, the probabilities of a strike to a metal-roofed structure are no more or less than any other kind of structure, as these probabilities have to do with height and size of the structure and its surroundings rather than its construction materials.

### **Consequence of a lightning strike**

In order to adequately assess risks involved with lightning events, the consequence of a strike must also be studied. In other words, what will happen if lightning does strike a subject building?

Obviously, there is a potential threat to human life associated with a lightning strike in addition to the threat of damage to either the contents of the building, the building itself, or both. These threats are affected by the following factors:

1. **Construction Materials:** Conductivity of both framing and roof covering materials is key to performance in case of a lightning strike. If these materials are (electrically) conductive, the electrical charge will pass through these materials and not build up heat through material resistance. The threat of fire and explosion are both reduced also reducing the threat to human life.
2. **Noncombustible Materials:** While the use of metal roofing will provide a conductive material that will transfer and dissipate the charge rather than build heat causing a potential fire, if the construction materials are noncombustible, the threat of damage due to fire is reduced. These materials will not contribute a fuel source to any fire resulting from a lightning strike.
3. **Building Contents:** The physical contents of the building can increase the overall risk. If the contents are flammable, the risk of a major fire or spread of fire to other portions of the building or between buildings is increased. If the contents are highly sensitive electronic or other equipment the possibility of damage due to arcing of an electrical charge can be quite high leading to loss of apparently untouched equipment.
4. **Building Occupancy:** High occupancy buildings such as schools and churches would be considered to be at a higher risk than unoccupied or sparsely occupied buildings. Not only is there danger posed by

the initial electrical charge, but the chance of fire and smoke is increased and poses a threat to human life.

5. **Building Location:** If the building is remote with respect to fire fighting and medical emergency response, the risks of physical loss due to fire as well as human perils are increased.

## **Summary**

Based on all of the available evidence, on any given building, a metal roof is no more or less likely to be struck by lightning than any other type of roofing material. In fact, a properly grounded metal roof, in accordance with the requirements of NFPA 780, will actually conduct the energy from a lightning strike over the broader area of the roof reducing the amount of heat transferred to the building and reducing the potential of damage due to fire. As an electrical conductor and a noncombustible material, the risks associated with use of a metal roof may even be a more desirable construction option.

It should still be stated that to minimize the risk of damage due to a lightning strike, it may in some cases, be prudent to consider additional lightning protection. A lightning protection system provides for a continuous conductor from sky to earth (and vice versa) so that the electrical charge is furnished a path of least resistance through which electrical energy can flow, thereby reducing the risk to (electrically) resistive construction materials and human life.

For additional information on the use of lightening protection, see NFPA 780 Standard for the Installation of Lightning Protection Systems. 2017 edition. National Fire Protection Association, Quincy, MA.

## **References**

- The Basis of Conventional Lightning Protection Technology; Report of the Federal Interagency Lightning Protection User Group June 2001.

- NFPA 78 Lightning Protection Code (Inactive)
- NFPA 780 Standard for the Installation of Lightning Protection Systems (2017)
- Development of the National Lightning Detection Network by Richard E Orville; American Meteorological Society (BAMS February 2008)

---

Founded in 1983, the Metal Construction Association brings together the diverse metal construction industry for the purpose of expanding the use of all metals used in construction. MCA promotes the benefits of metal in construction through:

- Technical guidance
- Product certification
- Educational and awareness programs
- Advocating for the interests of our industry
- Recognition of industry-achievement awards
- Monitoring of industry issues, such as codes and standards
- Research to develop improved metal construction products
- Promotional and marketing support for the metal construction industry
- Publications to promote use of metal wall and roof products in construction

For more information, please visit the MCA Web site at [www.metalconstruction.org](http://www.metalconstruction.org)

**Copyright © 2023 Metal Construction Association. All rights reserved.**

No part of this publication may be reproduced in any form or by any means, including photocopying, or utilized by any information storage or retrieval system without permission of the copyright owner.

This document is for general information only. The document is designed to delineate areas requiring consideration. Information contained in the document should not be used without first securing competent advice with respect to its suitability for any given application. MCA does not assume responsibility and disclaims any representation or warranty, express or implied, that such information is suitable for any general

or particular use. Anyone making use of the document assumes all liability resulting from such use.

The existence of the document does not in any respect preclude a member or nonmember of MCA from manufacturing, selling, or specifying products not conforming to the document, nor does the existence of an MCA document preclude its voluntary use by persons other than MCA members. The document does not purport to address all safety problems associated with its use or all applicable regulatory requirements. It is the responsibility of the user of the guideline to establish appropriate safety and health practices and to determine the applicability of regulatory limitations before use of the document.

The Metal Construction Association reserves the right to change, revise, add to, or delete any data contained in the document without prior notice.

It is the responsibility of the end user to verify the applicability of this information with the local building and fire officials.

© 04/23 V2

**METAL CONSTRUCTION ASSOCIATION**

8735 W. Higgins Road, Suite 300, Chicago, IL 60631

847.375.4718 | [mca@metalconstruction.org](mailto:mca@metalconstruction.org) | [www.metalconstruction.org](http://www.metalconstruction.org)

**BUILD LEGACIES**  
**METAL**